

Scope of Accreditation for Testing
Certificate No. 20T111/1089

Laboratory Name Kumwell Corporation Public Company Limited
 Address 26/2 Moo 10, Bangkruaisainoi Road, Banglen, Bangyai, Nonthaburi
 Accreditation No. TESTING 0631
 Laboratory Status Permanent Site Temporary Mobile

Field of Testing	Parameter	Test Method
Electrical field		
1. Air terminational conductors	<ul style="list-style-type: none"> - Electrical resistivity test - Tensile test - Bend test 	- IEC 62561-2 Edition 2.0 2018
2. Air terminational rods	<ul style="list-style-type: none"> - Electrical resistivity test - Tensile test - Bend test 	- IEC 62561-2 Edition 2.0 2018
3. Earth-lead in rods	<ul style="list-style-type: none"> - Electrical resistivity test - Tensile test - Bend test 	- IEC 62561-2 Edition 2.0 2018
4. Down-conductor	<ul style="list-style-type: none"> - Electrical resistivity test - Tensile test - Bend test 	- IEC 62561-2 Edition 2.0 2018
5. Earth electrodes	<ul style="list-style-type: none"> - Electrical resistivity test - Tensile strength test - Bend test - Adhesion test 	- IEC 62561-2 Edition 2.0 2018
6. Earth electrode inspection housing	<ul style="list-style-type: none"> - Load test 	- IEC 62561-5 Edition 2.0 2017

Issue date 25th June B.E. 2563 (2020)

(Signature)

(Mr. Verakit Rantakittanawat)
 Deputy Secretary - General
 For Secretary - General
 Thai Industrial Standards Institute